



Seekonk Water District

50 Water Lane, P.O. Box 97, Seekonk, Massachusetts 02771

Tel: (508) 761-8170 Fax: (508) 761-9928

June 27, 2011

Town of Seekonk
Planning Board

RE: Walmart Site Plan

Dear Planning Board Members:

The Seekonk Water District (SWD) has reviewed the above referenced plan and has the following comments:

- 1) The plan calls out a shutdown to cut in a 12"x12"x8" tee with a valve at the entrance to the site. The SWD recommends three (3) valves on the tee.
- 2) The proposed hydrant loop and water service requires a meter pit.
- 3) A standard detail must be provided for the several water / sewer crossings on the hydrant loop.
- 4) Provide details on the water service feeding the proposed WWTP.
- 5) The developer's fire insurer must provide certified maximum fire flow requirements in both gallons per minute and required pressure.

Please contact me with any questions or concerns.

Sincerely,

Robert Bernardo
Superintendent